

Discipline Function		BET Required Instrumentation (Effective January 1, 2021)																	
		RANGE				ACCURACY				RESOLUTION				Notes	Calibration Requirements				
Air	Air Pressure	0	in wg	to	10	in wg		2%	of reading	±	0.001	in wg	0.001	in wg	<	1	in wg		12 Months
													0.01	in wg	>	1	in wg		
	0	Pa	to	2500	Pa		2%	of reading	±	0.25	Pa	0.10	Pa	<	250	Pa			
													1	Pa	>	250	Pa		
Air Velocity Instrument		100	fpm	to	3500	fpm	±	5%	of reading	±	7	fpm	1	fpm					12 Months
		0.50	m/s	to	20	m/s	±	5%	of reading	±	0.04	m/s	0.01	m/s					
Temperature	Air Meter with probe	0	°F	to	200	°F	±	0.5%	of reading	+	2.0	°F	0.1	°F					12 Months
		-20	°C	to	100	°C	±	0.5%	of reading	+	1.0	°C	0.1	°C					
BET / RCx Instruments	Temp Documentation Thermal Camera	-4	°F	to	450	°F	±	2%		or	3.6	°F	0.1 @ 86 °F		&	160 x 120			Per Manufacturer's Requirements
		-20	°C	to	232	°C	±	2%		or	2.0°C	°C	0.1 @ 30 °C		&	160 x 120			
BET Instruments	Digital pressure flow measurement system	Not Applicable					±	4%	of reading				0.1 Pa (0.0004 inwc, 0.002 psf)					Per Manufacturer's Requirements	

NOTES

- *1 CPT Option - choose only Option 1 OR Option 2 - along with required instrument for CPT certification (All instruments in any of the chosen is required)
 - *2 FHT Orifice Calibrator - Choose only one
 - *3 Refer to Appendix A for complete instrumentation requirements for Sound Measurement (SM)
 - *4 Firms may own or rent vibration equipment instrumentation for vibration certification
 - *5 Calibration Requirement: Data logger calibration may be verified from a calibrated instrument with an associated calibration form showing calibration readings from both the calibrated instrument and the data logger. If a data logger is out of calibration and cannot be adjusted, the logger must be sent back to the factory for re-calibration or be replaced
 - *6 Accuracy of an instrument is either stated as a percentage of full scale or as a percentage of the reading. NEBB has chosen percentage of reading due to it being a more accurate reading. Since a % of reading error becomes smaller as you read near the lowest part of the scale the instrument resolution and accuracy must be very small to maintain the accuracy of the reading. To overcome this the manufactures add a standard offset to the % of reading to maintain a
- General Note:** Some local jurisdictions require qualified electrician for any electrical readings
- Calibration Requirement:** Instruments require NIST Traceable calibration or National Metrology Institutes (NMI) which exist in many countries maintaining primary measurements of standards; such as NPL in the UK, PTB in Germany and many others which are approved for those regions.